



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2361

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Bracken House	Date:	6/24/25
Address:	100 Anderson St. Pittsburgh, PA 15212	Time:	12:40 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

  

		<b><u>Sample Final Analysis</u></b>	
Matrix:	Recreational Water	Date:	6/27/25
Source Type:	Pool	Time:	9:20 AM
		Analyst:	1/0/00

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/25/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	12:40 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:40 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:40 PM	LM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2361

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

		<b><u>Sample Collection</u></b>	
Facility Name:	Bracken House	Date:	6/24/25
Address:	100 Anderson St. Pittsburgh, PA 15212	Time:	12:40 PM
Matrix:	Recreational Water	Method:	Grab
Source Type:	Pool		

**Sample Final Analysis**

Date: 6/27/25  
Time: 9:20 AM  
Analyst: 1/0/00

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/25/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	AS	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	12:40 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/24/25	12:40 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	12:40 PM	LM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor