Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2632

B & R Pools and Swim Shop

Customer

Facility Name:	*Oxford Court Apts*
Address:	*38 Oxford Court* *McCandless, PA 15237*
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/8/25*
Time:	2:31 PM
Method:	*Grab*

Sample Final Analysis

Date:	*7/11/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	2:31 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/25	2:31 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	2:31 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

Facility Name:	Oxford Court Apts
Address:	38 Oxford Court McCandless, PA 15237
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	7/8/25
Time:	2:31 PM
Method:	Grab

Sample Final Analysis

Date:	7/11/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	2:31 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/8/25	2:31 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	2:31 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor