



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 385

Customer

Facility Name: Residence Inn Forbes

Address: 3341 Forbes Ave
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/8/25

Time: 11:10 AM

Method: Grab

Sample Final Analysis

Date: 10/10/25

Time: 5:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/8/25	3:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/8/25	11:10 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/8/25	11:10 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/8/25	11:10 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor