



Lab ID No. 02-04041

**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Service

Lab# 012

**Customer**

Facility Name: Atrium  
Address: 307 South Dithridge  
Pittsburgh, PA 15213  
Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 1/12/26  
Time: 10:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 1/15/26  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	1/13/26	9:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/13/26	9:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/12/26	4:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	1/12/26	10:30 AM	RD	DPD
Chlorine:	2.8 mg/l	1.0 - 5.0 mg/l	1/12/26	10:30 AM	RD	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/12/26	10:30 AM	RD	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor