



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 492

Customer

Facility Name: Wildwood British Swim School

Address: 2344 Wildwood Rd.
Gibsonia, PA 15044

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/28/26

Time: 9:50 AM

Method: Grab

Sample Final Analysis

Date: 1/31/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26	12:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26	12:00 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/28/26	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	1/28/26	9:50 AM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	1/28/26	9:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/28/26	9:50 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)