



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 2387

**Customer**

Facility Name: Oxford Athletic  
Address: 100 Village Club Dr.  
Wexford, PA 15090  
Matrix: Recreational Water  
Source Type: Baby Pool

**Sample Collection**

Date: 6/24/25  
Time: 1:49 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/27/25  
Time: 9:20 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	11:20 AM	EB
Total coliforms:	0/100mls	2/100mls	6/25/25	11:20 AM	EB
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/24/25	1:49 PM	MM
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	1:49 PM	MM
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	1:49 PM	MM

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 2387

**Customer**

Facility Name: Oxford Athletic  
Address: 100 Village Club Dr.  
Wexford, PA 15090  
Matrix: Recreational Water  
Source Type: Baby Pool

**Sample Collection**

Date: 6/24/25  
Time: 1:49 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/27/25  
Time: 9:20 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	11:20 AM	EB
Total coliforms:	0/100mls	2/100mls	6/25/25	11:20 AM	EB
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/24/25	1:49 PM	MM
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	1:49 PM	MM
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	1:49 PM	MM

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor