



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 223

Customer

Facility Name: McKeesport H.S.

Address: 1960 Eden Park Blvd.
McKeesport, PA 15132

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/26/25
Time: 11:45 AM
Method: Grab

Sample Final Analysis

Date: 8/29/25
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/26/25	11:45 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	11:45 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	11:45 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor