



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

C-1

Lab# 333

**Customer**

Facility Name: Western PA School

Address: 201 N. Bellefield Ave.  
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Therapy Pool

**Sample Collection**

Date: 1/13/26

Time: 10:21 AM

Method: Grab

**Sample Final Analysis**

Date: 1/16/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/14/26	12:00 PM	JC
Total coliforms:	0/100mls	2/100mls	1/14/26	12:00 PM	JC
Standard plate count:	0/ml	200/ml	1/13/26	5:15 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	1/13/26	10:21 AM	SL
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	1/13/26	10:21 AM	SL
Turbidity:	1 NTU	1 - 2 NTU	1/13/26	10:21 AM	SL

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor