Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# **174**

Customer

Facility Name:	Hosanna House
Address:	807 Wallace Ave Pittsburgh, PA 15221
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	6/9/25
Time:	12:54 PM
Method:	Grab

Sample Final Analysis

Date:	6/12/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:38 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:54 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:54 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:54 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 174

Customer		*Sample Collection*	
Facility Name:	*Hosanna House*	*Date:*	*6/9/25*
		Time:	12:54 PM
Address:	*807 Wallace Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15221		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/12/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:38 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:54 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:54 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:54 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith