Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 378

Customer		**Sample Collection**	
Facility Name:	*Embassy Suite Hotel - Downtown*	*Date:*	*7/29/25*
		Time:	11:00 AM
Address:	*535 Smithfield St*	*Method:*	*Grab*
	Pittsburgh, PA 15222		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/1/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	11:00 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	11:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	11:00 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

C-11

Lab# 378

Customer

Facility Name: *Embassy Suite Hotel - Downtown*

Address: *535 Smithfield St*
Pittsburgh, PA 15222

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/29/25*
Time: 11:00 AM
Method: *Grab*

Sample Final Analysis

Date: *8/1/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	11:00 AM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	11:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	11:00 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor