



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 163

Customer

Facility Name: *Holiday Inn Express*

Address: *3695 State Route 31*
Donegal, PA 15628

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *12/16/25*

Time: *10:21 AM*

Method: *Grab*

Sample Final Analysis

Date: *12/19/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/17/25 9:30 AM	AS	SM 9222G
-------------------	--------	--------	------------------	----	----------

Total coliforms:	0/100mls	2/100mls	12/17/25 9:30 AM	AS	SM 9222B
------------------	----------	----------	------------------	----	----------

Standard plate count:	100/ml	200/ml	12/16/25 3:15 PM	AS	SM 9215B
-----------------------	--------	--------	------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/17/25 11:15 AM	AS	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.2 SU	7.2 - 7.8 SU	12/16/25 10:21 AM	JC	DPD
-----	--------	--------------	-------------------	----	-----

Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/16/25 10:21 AM	JC	DPD
-----------	----------	----------------	-------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	12/16/25 10:21 AM	JC	Visual
------------	-------	-----------	-------------------	----	--------

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)