Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2507

Customer		**_Sample Collection_**	
Facility Name:	*Stanford Court*	*Date:*	7/2/25
		Time:	8:00 AM
Address:	*1200 Stanford Ct.*	*Method:*	*Grab*
	Coraopolis, PA 15108		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/4/25*
		Time:	*3:30 PM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/2/25	8:00 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/2/25	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	8:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2507

**Customer**		_**Sample Collection**_		
Facility Name:	*Stanford Court*	*Date:*	*7/2/25*	
		Time:	8:00 AM	
Address:	*1200 Stanford Ct.*	*Method:*	*Grab*	
	Coraopolis, PA 15108			
		**Sample Final Analysis**		
Matrix:	*Recreational Water*	*Date:*	*7/4/25*	
		Time:	3:30 PM	
Source Type:	*Pool*	*Analyst:*	AS	

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/2/25	8:00 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/2/25	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	8:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor