



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 500

Customer

Facility Name: Ditheridge House
Address: 220 N. Ditheridge St
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/16/25
Time: 9:44 AM
Method: Grab

Sample Final Analysis

Date: 12/19/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/17/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/17/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/16/25	3:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/16/25	9:44 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/16/25	9:44 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/16/25	9:44 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor