Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# _2455_

Customer

		Sample Collection	
Facility Name:	Rosslyn Farms	*Date:*	6/18/25
		Time:	10:30 AM
Address:	200 Rosslyn Rd	*Method:*	Grab
	Carnegie, PA 15106		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	6/20/25
		Time:	3:30 PM
Source Type:	Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	4:05 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	4:05 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/18/25	4:05 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/18/25	10:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/18/25	10:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/18/25	10:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# *2455*

Customer

Facility Name:	*Rosslyn Farms*
Address:	*200 Rosslyn Rd*
	Carnegie, PA 15106
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/18/25*
Time:	10:30 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/20/25*
Time:	*3:30 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	4:05 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	4:05 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/18/25	4:05 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/18/25	10:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/18/25	10:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/18/25	10:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor