



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

S-12

Lab# 074

Customer

Facility Name: *Courtyard by Marriott*
Address: *401 West Waterfront Drive
West Homestead, PA 15120*
Matrix: *Recreational Water*
Source Type: *Spa*

Sample Collection

Date: *7/7/25*
Time: *10:00 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:00 AM	EB
Total coliforms:	0/100mls	2/100mls	7/8/25	10:00 AM	EB
Standard plate count:	300/ml	200/ml	7/7/25	4:45 PM	EB

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/8/25	11:40 AM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25	10:00 AM	SL
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	10:00 AM	SL
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	10:00 AM	SL

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

S-12

Lab# 074

Customer

Facility Name: *Courtyard by Marriott*
Address: *401 West Waterfront Drive
West Homestead, PA 15120*
Matrix: *Recreational Water*
Source Type: *Spa*

Sample Collection

Date: *7/7/25*
Time: *10:00 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:00 AM	EB
Total coliforms:	0/100mls	2/100mls	7/8/25	10:00 AM	EB
Standard plate count:	300/ml	200/ml	7/7/25	4:45 PM	EB

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/8/25	11:40 AM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/7/25	10:00 AM	SL
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	10:00 AM	SL
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	10:00 AM	SL

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor