



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 478

Customer

Facility Name: Comfort Inn Duncansville

Address: 130 Patchway Rd.
Duncansville, PA 16635

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 10/27/25

Time: 12:40 PM

Method: Grab

Sample Final Analysis

Date: 10/30/25

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	10/28/25 12:00 PM	JC	SM 9222G
-------------------	--------	--------	-------------------	----	----------

Total coliforms:	0/100mls	2/100mls	10/28/25 12:00 PM	JC	SM 9222B
------------------	----------	----------	-------------------	----	----------

Standard plate count:	100/ml	200/ml	10/27/25 5:44 PM	SL	SM 9215B
-----------------------	--------	--------	------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	10/28/25 12:30 PM	JC	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	10/27/25 12:40 PM	DNP	DPD
-----	--------	--------------	-------------------	-----	-----

Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/27/25 12:40 PM	DNP	DPD
-----------	----------	----------------	-------------------	-----	-----

Turbidity:	1 NTU	1 - 2 NTU	10/27/25 12:40 PM	DNP	Visual
------------	-------	-----------	-------------------	-----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor