



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2449

Customer

Facility Name: Rodgers-McFeely

Sample Collection

Date: 7/14/25

Address: 910 Jefferson Street
Latrobe, PA 15650

Time: 2:28 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Source Type: Pool

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	2:28 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	2:28 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	2:28 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2449

Customer

Facility Name: Rodgers-McFeely

Sample Collection

Date: 7/14/25

Address: 910 Jefferson Street
Latrobe, PA 15650

Time: 2:28 PM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 7/17/25

Source Type: Pool

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	2:28 PM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/14/25	2:28 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	2:28 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith