Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# _324_

Customer

Facility Name:	*Verland Foundation*
Address:	*212 Iris Rd.*
	Sewickley, PA 15143
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/23/25*
Time:	11:30 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/25/25*
Time:	*2:00 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/23/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/23/25	11:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/23/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/23/25	11:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith
Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# _324_

Customer

Facility Name:	*Verland Foundation*
Address:	*212 Iris Rd.*
	Sewickley, PA 15143
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/23/25*
Time:	11:30 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/25/25*
Time:	*2:00 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	3:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/23/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/23/25	11:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/23/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/23/25	11:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith
Andre Smith, Lead Supervisor