



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM

Lab# 467

C1

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Here Apts*

Address: *3506 Forbes Ave*
 Pittsburgh, PA 15213

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *10/28/25*
Time: *2:03 PM*
Method: *Grab*

Sample Final Analysis

Date: *10/31/25*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/29/25 10:00 AM	SL	SM 9222G

Total coliforms:	0/100mls	2/100mls	10/29/25 10:00 AM	SL	SM 9222B
------------------	----------	----------	------------------------	----	----------

Standard plate count:	0/ml	200/ml	10/28/25 4:30 PM	SL	SM 9215B
-----------------------	------	--------	-----------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	10/29/25 10:30 AM	SL	SM 9230C
---------------------	----------	----------	------------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	10/28/25 2:03 PM	SL	DPD
-----	--------	--------------	-----------------------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/28/25 2:03 PM	SL	DPD
-----------	----------	----------------	-----------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	10/28/25 2:03 PM	SL	Visual
------------	-------	-----------	-----------------------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor