



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N - 1**

**Lab# 388**

**Customer**

**Facility Name:** Towne Place Suites  
**Address:** 2020 Cool Springs Dr.  
Cranberry Township, PA 16066

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 9/2/25  
**Time:** 11:10 AM  
**Method:** Grab

**Sample Final Analysis**


**Date:** 9/5/25  
**Time:** 10:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 9/3/25 12:00 PM      | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 9/3/25 12:00 PM      | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 9/2/25 5:55 PM       | AS      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time       | Analyst | Method |
|----------------|-----------|-----------------|-----------------|---------|--------|
| pH:            | 8.0 SU    | 7.2 - 7.8 SU    | 9/2/25 11:10 AM | BH      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 9/2/25 11:10 AM | BH      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 9/2/25 11:10 AM | BH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

  
Andre Smith, Lead Supervisor