

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Method:

Lab ID No. 02-04041 **N-14**

Lab# 2666

Grab

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Danbury Farms Date: 7/14/25
Time: 12:00 PM

Address: 100 Carriage Dr Freedom, PA 15042

Matrix: Recreational Water Sample Final Analysis

Date: 7/17/25

Source Type: Pool Time: 8:30 AM
Analyst: AS

Accredited Analysis Results **Reporting limit Analyst Incubation Date/Time** Method Escherichia Coli: Absent Absent 7/15/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/15/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 7/14/25 3:53 PM EΒ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.6 SU	7.2 - 7.8 SU	7/14/25	12:00 PM	ZR	DPD	
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/14/25	12:00 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:00 PM	ZR	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Method:

Lab ID No. 02-04041 **N-14**

Lab# 2666

Grab

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Danbury Farms Date: 7/14/25
Time: 12:00 PM

Address: 100 Carriage Dr Freedom, PA 15042

Matrix: Recreational Water Sample Final Analysis

Date: 7/17/25

Source Type: Pool Time: 8:30 AM
Analyst: AS

Accredited Analysis Results **Reporting limit Analyst Incubation Date/Time** Method Escherichia Coli: Absent Absent 7/15/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/15/25 9:30 AM EΒ SM 9222B Standard plate count: 0/ml 200/ml 7/14/25 3:53 PM EΒ SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.6 SU	7.2 - 7.8 SU	7/14/25	12:00 PM	ZR	DPD	
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	7/14/25	12:00 PM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	12:00 PM	ZR	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith