



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2229**

**Customer**

**Facility Name:** *Glen's Pool*

**Address:** *100 Inverness Dr.*  
*Pittsburgh, PA 15237*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/10/25*

**Time:** *1:52 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/13/25*

**Time:** *9:30 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	1:52 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	1:52 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	1:52 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2229**

**Customer**

**Facility Name:** *Glen's Pool*

**Address:** *100 Inverness Dr.*  
*Pittsburgh, PA 15237*

**Matrix:** *Recreational Water*

**Source Type:** *Pool*

**Sample Collection**

**Date:** *6/10/25*

**Time:** *1:52 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/13/25*

**Time:** *9:30 AM*

**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	1:52 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	1:52 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	1:52 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor