



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2665

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/8/25
Time: 10:03 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Facility Name: Georgetown Estates
Address: Old Farm Rd.
Lawrence, PA 15055

Matrix: Recreational Water
Source Type: Large Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	10:03 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	10:03 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	10:03 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2665

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Georgetown Estates
Address: Old Farm Rd.
Lawrence, PA 15055

Date: 7/8/25
Time: 10:03 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Large Pool

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	10:03 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	10:03 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	10:03 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor