



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 241

Customer

Facility Name: *Obama High School*

Address: *515 N. Highland Ave
Pittsburgh, PA 15206*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *7/1/25*

Time: *9:03 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/4/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/2/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	7/2/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	A	7/1/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.4 SU	A	7/1/25	9:03 AM	SL	DPD
Chlorine:	2.0 mg/l	B	7/1/25	9:03 AM	SL	DPD
Turbidity:	1 NTU	A	7/1/25	9:03 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 241

Customer

Facility Name: *Obama High School*
Address: *515 N. Highland Ave*
Pittsburgh, PA 15206

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *7/1/25*
Time: *9:03 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/4/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	7/2/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	7/2/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	A	7/1/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.4 SU	A	7/1/25	9:03 AM	SL	DPD
Chlorine:	2.0 mg/l	B	7/1/25	9:03 AM	SL	DPD
Turbidity:	1 NTU	A	7/1/25	9:03 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor