



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-1**

**Lab# 183**

**Customer**

Facility Name: *Imperial House*  
  
Address: *5600 Munhall Rd.*  
*Pittsburgh, PA 15217*

Matrix: *Recreational Water*  
  
Source Type: *Pool*

**Sample Collection**

Date: *12/1/25*  
Time: *1:36 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *12/4/25*  
Time: *11:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/2/25	10:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/2/25	10:55 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/1/25	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/1/25	1:36 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/1/25	1:36 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/1/25	1:36 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor