



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 163**

**Customer**

Facility Name: *Holiday Inn Express*

Address: *3695 State Route 31*  
*Donegal, PA 15628*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *2/2/26*

Time: *10:03 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *2/5/26*

Time: *10:30 AM*

Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 2/3/26 10:00 AM      | JC      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 2/3/26 10:00 AM      | JC      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 2/2/26 4:10 PM       | SL      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 2/3/26 11:00 AM      | JC      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            | Analyst | Method   |
| pH:                   | 7.4 SU   | 7.2 - 7.8 SU    | 2/2/26 10:03 AM      | JC      | DPD      |
| Chlorine:             | 1.0 mg/l | 1.0 - 5.0 mg/l  | 2/2/26 10:03 AM      | JC      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 2/2/26 10:03 AM      | JC      | Visual   |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)