



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 175

Customer

Facility Name: Hyatt House - South Side

Address: 2795 South Water St.
Pittsburgh, PA 15603

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/25

Time: 3:00 PM

Method: Grab

Sample Final Analysis

Date: 7/25/25

Time: 12:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/23/25 | 11:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/23/25 | 11:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/22/25 | 5:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/22/25 | 3:00 PM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/22/25 | 3:00 PM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 | 3:00 PM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 175

Customer

Facility Name: Hyatt House - South Side

Address: 2795 South Water St.
Pittsburgh, PA 15603

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/22/25

Time: 3:00 PM

Method: Grab

Sample Final Analysis

Date: 7/25/25

Time: 12:00 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/23/25 | 11:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/23/25 | 11:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/22/25 | 5:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/22/25 | 3:00 PM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/22/25 | 3:00 PM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 | 3:00 PM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor