



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 224**

**Customer**

Facility Name: *McKeesport High School*

Address: *1960 Eden Park Blvd.*  
*McKeesport, PA 15132*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

**Sample Collection**

Date: *11/3/25*

Time: *3:15 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *11/6/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/4/25	9:50 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/4/25	9:50 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/3/25	4:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	11/3/25	3:15 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	11/3/25	3:15 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/3/25	3:15 PM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor