



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2084

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Castle Creek*

Date: *7/22/25*

Address: *100 Castle Creek Drive*
Seven Fields PA 16046

Time: *10:40 AM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *7/25/25*

Source Type: *Pool*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	10:40 AM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:40 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:40 AM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2084

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Castle Creek*

Date: *7/22/25*

Address: *100 Castle Creek Drive*
Seven Fields PA 16046

Time: *10:40 AM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *7/25/25*

Source Type: *Pool*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	10:40 AM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:40 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:40 AM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor