

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 107

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Franklin Regional Middle School Date: 9/3/25

Address: 3200 School Rd. Time: 12:20 PM
Method: Grab

Murrysville, PA 15668

Matrix: Recreational Water Sample Final Analysis

Date: 9/6/25

Source Type: Pool Time: 2:00 PM
Analyst: AS

Accredited Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 9/4/25 9:15 AM JC SM 9222G Total coliforms: 0/100mls 2/100mls 9/4/25 9:15 AM JC SM 9222B Standard plate count: SL SM 9215B 0/ml 200/ml 9/3/25 4:15 PM

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/3/25	12:20 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/3/25	12:20 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/25	12:20 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor