



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2002**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/4/25*  
*Time: 8:40 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/7/25*  
*Time: 11:20 AM*  
*Analyst: AS*

*Facility Name: Eastside Bond*  
*Address: 6015 Spirit St.*  
*Pittsburgh, PA 15206*  
  
*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	3:15 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	8:40 AM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	8:40 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	8:40 AM	LM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2002**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Date: 8/4/25*  
*Time: 8:40 AM*  
*Method: Grab*

**Sample Final Analysis**

*Date: 8/7/25*  
*Time: 11:20 AM*  
*Analyst: AS*

*Facility Name: Eastside Bond*  
*Address: 6015 Spirit St.*  
*Pittsburgh, PA 15206*  
  
*Matrix: Recreational Water*  
*Source Type: Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	9:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	9:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	3:15 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	8:40 AM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	8:40 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	8:40 AM	LM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor