



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2598

Customer

Facility Name: Woodland Hills Club
Address: 2799 Bingham Drive
Upper St. Claire, PA 15241

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 5/27/25
Time: 1:54 PM
Method: Grab

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 10:15 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 10:15 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/27/25 | 1:54 PM | AF | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 1:54 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 1:54 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2598

Customer

Facility Name: Woodland Hills Club
Address: 2799 Bingham Drive
Upper St. Claire, PA 15241

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 5/27/25
Time: 1:54 PM
Method: Grab

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 10:15 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 10:15 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/27/25 | 1:54 PM | AF | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 1:54 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 1:54 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor