

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: The View@North Hills

1000 Johanna Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Results

Source Type: Pool

Accredited Analysis

Address:

Sample Collection

Date: 6/9/25

Time: 11:42 AM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 6/12/25

 Time:
 9:30 AM

Analyst: AS

Analyst

Method

		<u> </u>				
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	6/9/25	5:40 PM	SL	SM 9215B

Reporting limit

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	11:42 AM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/9/25	11:42 AM	ММ	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	11:42 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: The View@North Hills

1000 Johanna Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Results

Source Type: Pool

Accredited Analysis

Address:

Sample Collection

Date: 6/9/25

Time: 11:42 AM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 6/12/25

 Time:
 9:30 AM

Analyst: AS

Analyst

Method

		<u> </u>				
Escherichia Coli:	Absent	Absent	6/10/25	10:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:10 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	6/9/25	5:40 PM	SL	SM 9215B

Reporting limit

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	11:42 AM	MM	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/9/25	11:42 AM	ММ	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	11:42 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor