Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 2541

Customer		*Sample Collection*	
Facility Name:	*Valley Brook Country Club*	*Date:*	*7/1/25*
		Time:	*9:58 AM*
Address:	*4 Hidden Valley Road*	*Method:*	*Grab*
	Canonsburg, PA 15317		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/4/25*
		Time:	*9:30 AM*
Source Type:	*Deep End*	*Analyst:*	*#REF!*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	9:58 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:58 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:58 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 2541

Customer		**Sample Collection**
Facility Name:	*Valley Brook Country Club*	*Date:* 7/1/25
		Time: 9:58 AM
Address:	*4 Hidden Valley Road*	*Method:* Grab
	Canonsburg, PA 15317	
		Sample Final Analysis
Matrix:	*Recreational Water*	*Date:* 7/4/25
		Time: 9:30 AM
Source Type:	*Deep End*	*Analyst:* #REF!

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	11:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	11:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	9:58 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/1/25	9:58 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	9:58 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor