



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-11**

**Lab# 000**

**Customer**

**Facility Name:** Camp Deer Creek  
**Address:** 109 Eisele Road  
Cheswick, PA 15024

**Matrix:** Recreational Water

**Source Type:** Creek

**Sample Collection**

**Date:** 6/24/25  
**Time:** 3:05 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/27/25  
**Time:** 9:20 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	5/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	6/24/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/24/25	3:05 PM	SH	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	6/24/25	3:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	3:05 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-11**

**Lab# 000**

**Customer**

**Facility Name:** Camp Deer Creek  
**Address:** 109 Eisele Road  
Cheswick, PA 15024

**Matrix:** Recreational Water

**Source Type:** Creek

**Sample Collection**

**Date:** 6/24/25  
**Time:** 3:05 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/27/25  
**Time:** 9:20 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Present	Absent	6/25/25	10:15 AM	EB	SM 9222G
Total coliforms:	5/100mls	2/100mls	6/25/25	10:15 AM	EB	SM 9222B
Standard plate count:	5700/ml	200/ml	6/24/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/24/25	3:05 PM	SH	DPD
Chlorine:	NA	1.0 - 5.0 mg/l	6/24/25	3:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	3:05 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor