



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 312

Customer

Facility Name: UPMC Lemieux Sports Complex

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge

Sample Collection

Date: 8/5/25

Time: 9:40 AM

Method: Grab

Sample Final Analysis

Date: 8/8/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 3:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 3:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/5/25 9:40 AM	JR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25 9:40 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 9:40 AM	JR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 312

Customer

Facility Name: UPMC Lemieux Sports Complex

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge

Sample Collection

Date: 8/5/25

Time: 9:40 AM

Method: Grab

Sample Final Analysis

Date: 8/8/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25 3:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25 3:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25 6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/5/25 9:40 AM	JR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25 9:40 AM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25 9:40 AM	JR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor