



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *810 Highland Meadow Dr.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *7/29/25*  
**Time:** *12:37 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *8/1/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

**Source Type:** *Spa*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Fecal Streptococcus	0/100mls	2/100mls	7/30/25	10:50 AM	EB	SM 9230C
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	12:37 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/29/25	12:37 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	12:37 PM	GR	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*  
**Address:** *810 Highland Meadow Dr.*  
*Washington, PA 15301*

**Sample Collection**

**Date:** *7/29/25*  
**Time:** *12:37 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *8/1/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

**Source Type:** *Spa*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B
<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Fecal Streptococcus	0/100mls	2/100mls	7/30/25	10:50 AM	EB	SM 9230C
<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	12:37 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/29/25	12:37 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	12:37 PM	GR	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor