



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**

Lab ID No. 02-04041

W-2

Lab# 150

## Laboratory Analysis Report

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Hilton Garden Inn	Date:	9/9/25			
Address:	303 Park Manor Dr. Pittsburgh, PA 15205	Time:	9:30 AM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	9/12/25			
	Pool	Time:	10:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	9/10/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/25	2:30 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	9/9/25	9:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/9/25	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/25	9:30 AM	VH	Visual

### Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor