



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 252

Customer

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *8/4/25*

Time: *12:48 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/25*

Time: *11:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	A	8/4/25	4:55 PM	AH	SM 9215B

Field Analysis	Results	Rating		Date/Time	Analyst	Method
pH:	7.9 SU	D	8/4/25	12:48 PM	ZS	DPD
Chlorine:	8.0 mg/l	E	8/4/25	12:48 PM	ZS	DPD
Turbidity:	1 NTU	A	8/4/25	12:48 PM	ZS	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 252

Customer

Facility Name: Perry Traditional Academy

Address: 3875 Perrysville Ave.
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 8/4/25

Time: 12:48 PM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	A	8/4/25	4:55 PM	AH	SM 9215B

Field Analysis	Results	Rating		Date/Time	Analyst	Method
pH:	7.9 SU	D	8/4/25	12:48 PM	ZS	DPD
Chlorine:	8.0 mg/l	E	8/4/25	12:48 PM	ZS	DPD
Turbidity:	1 NTU	A	8/4/25	12:48 PM	ZS	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor