



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 471

Customer

Facility Name: *Holiday Inn*

Address: *115 Convention Center Dr.*
Duncansville, PA 16635

Sample Collection

Date: *1/20/26*
Time: *1:00 PM*
Method: *Grab*

Sample Final Analysis

Date: *1/23/26*
Time: *11:30 AM*
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/21/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/21/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/20/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	1/20/26	1:00 PM	DNP	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	1/20/26	1:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/20/26	1:00 PM	DNP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor