



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041
C-2

Lab# 446

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Comfort Inn	Date:	11/25/25			
Address:	830 East Ohio St. Pittsburgh, PA 15222	Time:	12:00 AM			
Matrix:	Recreational Water	Method:	Grab			
Source Type:	Pool					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	11/26/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/26/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/25/25	4:45 PM	AS	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	8.0 SU	7.2 - 7.8 SU	11/25/25	12:45 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	11/25/25	12:45 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/25/25	12:45 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor