



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2494**

**Customer**

Facility Name: South Hills Country Club

Address: 4305 Brownsville Road  
Pittsburgh, PA 15236

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 6/16/25

Time: 2:10 PM

Method: Grab

**Sample Final Analysis**

Date: 6/19/25

Time: 10:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/17/25              | 12:00 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/17/25              | 12:00 PM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/16/25              | 6:00 PM  | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 6/16/25   | 2:10 PM | DW      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 6/16/25   | 2:10 PM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/16/25   | 2:10 PM | DW      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2494**

**Customer**

**Facility Name:** South Hills Country Club

**Address:** 4305 Brownsville Road  
Pittsburgh, PA 15236

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 6/16/25

**Time:** 2:10 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 6/19/25

**Time:** 10:00 AM

**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/17/25              | 12:00 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/17/25              | 12:00 PM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/16/25              | 6:00 PM  | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 6/16/25   | 2:10 PM | DW      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 6/16/25   | 2:10 PM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/16/25   | 2:10 PM | DW      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor