



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 131

Laboratory Analysis Report

Customer

Facility Name: Hampton Inn & Suites - Settlers Ridge

Address: 5000 Campbells Run Rd.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 2/3/26

Time: 11:45 AM

Method: Grab

Sample Final Analysis

Date: 2/6/26

Time: 10:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 2/4/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 2/4/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 2/3/26 | 3:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 2/3/26 | 11:45 AM | VH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 2/3/26 | 11:45 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 2/3/26 | 11:45 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor