



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 172

Customer

Facility Name: Homewood Suites
Address: 3000 Horizon Vue Dr.
Cannonsburg, PA 15317

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 2/16/26
Time: 11:11 AM
Method: Grab

Sample Final Analysis

Date: 2/18/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	2/17/26 10:00 AM	SL	SM 9222G
-------------------	--------	--------	------------------	----	----------

Total coliforms:	0/100mls	2/100mls	2/17/26 10:00 AM	SL	SM 9222B
------------------	----------	----------	------------------	----	----------

Standard plate count:	0/ml	200/ml	2/16/26 3:40 PM	SL	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	2/17/26 12:00 PM	SL	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	2/16/26 11:11 AM	GR	DPD
-----	--------	--------------	------------------	----	-----

Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	2/16/26 11:11 AM	GR	DPD
-----------	-----------	----------------	------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	2/16/26 11:11 AM	GR	Visual
------------	-------	-----------	------------------	----	--------

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)