



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 477

Customer

Facility Name: *Comfort Inn Duncansville*
Address: *130 Patchway Rd.*
Duncansville, PA 16635

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/9/25*
Time: *12:40 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/12/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	11:15 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	6/9/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:40 PM	DP	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:40 PM	DP	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:40 PM	DP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 477

Customer

Facility Name: *Comfort Inn Duncansville*
Address: *130 Patchway Rd.*
Duncansville, PA 16635

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/9/25*
Time: *12:40 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/12/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	11:15 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	6/9/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:40 PM	DP	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:40 PM	DP	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:40 PM	DP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor