



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2519**

**Customer**

**Facility Name:** Sunridge  
**Address:** 1 Sunridge Dr.  
Champion, PA 15622

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 8/11/25  
**Time:** 10:51 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/14/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	12:00 AM	EB	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	10:51 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/11/25	10:51 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	10:51 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2519**

**Customer**

**Facility Name:** Sunridge  
**Address:** 1 Sunridge Dr.  
Champion, PA 15622

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 8/11/25  
**Time:** 10:51 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/14/25  
**Time:** 9:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	12:00 AM	EB	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	10:51 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/11/25	10:51 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	10:51 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor