

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 399

Customer

Facility Name: Stay Bridge Suites

915 Brush Creek Rd. Address:

Warrendale, PA 15086

Matrix: Recreational Water

Source Type: Pool Sample Collection

Date: 7/14/25 Time: 10:05 AM

Method: Grab

Sample Final Analysis

Time:

Date: 7/17/25 8:30 AM

Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/15/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/15/25 9:30 AM EΒ SM 9222B Standard plate count: 125/ml 200/ml 7/14/25 3:53 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 7/14/25 | 10:05 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 10:05 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 10:05 AM | ZR | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 399

Customer

Facility Name: Stay Bridge Suites

915 Brush Creek Rd. Address:

Warrendale, PA 15086

Matrix: Recreational Water

Source Type: Pool Sample Collection

Date: 7/14/25 Time: 10:05 AM

Method: Grab

Sample Final Analysis

Time:

Date: 7/17/25 8:30 AM

Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/15/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 7/15/25 9:30 AM EΒ SM 9222B Standard plate count: 125/ml 200/ml 7/14/25 3:53 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 7/14/25 | 10:05 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 10:05 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 10:05 AM | ZR | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith