Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2393

B & R Pools and Swim Shop

Customer

Facility Name:	*Park Swim Club*
Address:	*College Park Dr.*
	Monroeville, PA 15146
Matrix:	*Recreational Water*
Source Type:	*Shallow End*

Sample Collection

Date:	*7/15/25*
Time:	*12:46 PM*
Method:	*Grab*

Sample Final Analysis

Date:	*7/18/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	12:46 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25	12:46 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	12:46 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2393

Customer
Facility Name: *Park Swim Club*

Address: *College Park Dr.*
Monroeville, PA 15146

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection
Date: *7/15/25*
Time: 12:46 PM
Method: *Grab*

Sample Final Analysis
Date: *7/18/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	12:46 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/25	12:46 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	12:46 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor