

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-10

Lab ID No. 02-04041

Lab# 2381

Sample Collection Customer

Facility Name: O'Hara Woods Club 6/10/25 Date: Time: 1:30 PM Address: 100 O'Hara Woods Dr. Method: Grab

Pittsburgh, PA 15238

Sample Final Analysis Matrix: Recreational Water Date: 6/13/25

Time: 9:30 AM Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25	1:30 PM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	1:30 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	1:30 PM	ВН	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-10

Lab ID No. 02-04041

Lab# 2381

Sample Collection Customer

Facility Name: O'Hara Woods Club 6/10/25 Date: Time: 1:30 PM Address: 100 O'Hara Woods Dr. Method: Grab

Pittsburgh, PA 15238

Sample Final Analysis Matrix: Recreational Water Date: 6/13/25

Time: 9:30 AM Source Type: Pool Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/10/25	1:30 PM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	1:30 PM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	1:30 PM	ВН	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith