



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

N-17

Laboratory Analysis Report Lab# 453

**Customer**

Facility Name: Fairfield Inn Butler

Address: 200 Fairfield Ln  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/4/25

Time: 12:25 PM

Method: Grab

**Sample Final Analysis**

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/4/25	12:25 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:25 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

N-17

Laboratory Analysis Report Lab# 453

**Customer**

Facility Name: Fairfield Inn Butler

Address: 200 Fairfield Ln  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 8/4/25

Time: 12:25 PM

Method: Grab

**Sample Final Analysis**

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	12:15 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	12:15 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	7:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/4/25	12:25 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:25 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor